

Pump Station 26



Pump Station 26

Pump Upstream of Pump Station
Intake



Pump Station 26

Bypass Pump Discharge
Connection Point



Pump Station 26

Vertical Turbine Pump Motor
Totally Enclosed Fan Cooled
(TEFC)
Suitable for Class 1, Division 2

Note open termination box

Pump Station 26



Pump Station 26

Discharge Check and Isolation
(Gate) Valves
Note Open Connection to Wet Well

Wet Well NEC Classification: Class
1, Division 2



Pump Station 26

Discharge Isolation (Gate) Valve



Pump Station 26

Level Control – note open
connection to Wet Well

Pump Station 26



Pump Station 26

Wood Cover Over Wet Well –
Provides Access to Pump
Discharge Valves

Electrical Panels – not rated for
NEC Class 1 Division 2



Pump Station 26

Electrical Panels – not rated for
NEC Class 1 Division 2



Pump Station 26

Heater and Dehumidifier